



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

Date of Report: 18/03/07

Sample ID No.8021614-01

Laboratory

Signature Lab

Name: PRECISION ENVIRO-TECH ANALYTICAL LAB

Director: *Handwritten Signature*

Name of Sampler:SW

Employed By: Aqualab

Date/Time Sample

Date/Time Sample

Date Analyses

Collected:18/02/15/1349

Received @ Lab:18/02/16/1210

Completed:18/02/22

System

System

Name:SIERRA PARK WATER COMPANY, INC.

Number: 5510016

Name or Number of Sample Source:WELL 05

* User ID: AGE

Station Number: 5510016-006

* Date/Time of Sample: |18|02|15|1349|

Laboratory Code: 2213

* YY MM DD TTTT

YY MM DD

* Date Analysis completed: |18|02|22|

* Submitted by: _____

Phone #: _____

PAGE 1 OF 1

INORGANIC CHEMICALS

MCL	REPORTING	CHEMICAL	ENTRY	ANALYSES	DLR
	UNITS		#	RESULTS	
50	ug/L+	Manganese (Mn) (ug/L)	01055	193	20.0

+ Indicates Secondary Drinking Water Standards



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

Date of Report: 18/03/07 Sample ID No.8021614-02
 Laboratory Signature Lab
 Name: PRECISION ENVIRO-TECH ANALYTICAL LAB Director: Harsh
 Name of Sampler: SW Employed By: Aqualab
 Date/Time Sample Date/Time Sample Date Analyses
 Collected: 18/02/15/1345 Received @ Lab: 18/02/16/1210 Completed: 18/02/22

System System
 Name: SIERRA PARK WATER COMPANY, INC. Number: 5510016
 Name or Number of Sample Source: WELL 06

 * User ID: AGE Station Number: 5510016-007 *
 * Date/Time of Sample: |18|02|15|1345| Laboratory Code: 2213 *
 * YY MM DD TTTT YY MM DD *
 * Submitted by: _____ Date Analysis completed: |18|02|22| *
 * Phone #: _____ *

PAGE 1 OF 1 INORGANIC CHEMICALS

MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
300	ug/L+	Iron (Fe) (ug/L)	01045	1650	100.0
50	ug/L+	Manganese (Mn) (ug/L)	01055	298	20.0

+ Indicates Secondary Drinking Water Standards