

AquaLab Water Analysis
 P.O. Box 356
 Twain Harte CA 95383

State Certification # 1359
 (209) 586-3400
 Fax: (209) 586-1492

BACTERIOLOGICAL EXAMINATION OF WATER

SIERRA PARK WATER CO
 ODDFELLOWS SIERRA
 P O BOX 424
 MI WUK VILLAGE CA 95346

5510016 SWRCB
 e) GROUP

DAVE ROY 770-0109
 Yvonne 586-5950 Ron 586-4528

Date: **11-04-20**

Sampler: **Feb**

Source			Reason			Type						
1) Surface/ Spring	4) Reservoir	A) Routine	C) Total Coliform	2) Well Head	5) Distribution	B) Repeat	F) Fecal Coliform	3) Well Distribution	6) Treatment Plant	C) Special	H) Heterotrophic Plate Count	E) <i>E. coli</i>

5332-E Collection Data Five Portions sm 9221 Presence/Absence sm 9223B

Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol mL	# Positive Tubes							Coliform			CFU mL 35 C @ 48HR	
								Prsmp		Confirmed				#	P/A or MPN				
								24	48	24	24	48	48		Total	Fecal	E.coli		
		25418 WHEELER (JAJO)		3	A	C	20.0												
E 4#F	1030	25149 ABRAHAM (FMAN)	20.05	3	A	C	20.0	00							0	<1.1			
		25259 REBEKAH (MJSD)		3	A	C	20												

Notification/Comments/Transported @ < 10 degree C

Set-Up: Date/Time/By: **11-4 1415 LLJ**

Completed: Date/By: **11-6-2020 JEF**

These Tests Do Meet State Standards
 Do Not