

Aqualab

P.O. BOX 356
Twain Harte, CA 95383
(209) 586-3400

CERTIFICATE OF ANALYSIS

Page 2 of 4

Attention: Dave Roy
Sierra Park Water Co/Oddfellows Sierra
PO Box 424
Mi Wuk Village, CA 95346

Microbiological Parameters by APHA Standard Methods Analytical Report Sample Results

Sample Information

Laboratory ID: A1K0321-01
Sample ID: 25149 Abraham
Date/ Time Sampled Received: 11/3/2021 12:30:00PM
Project Name & No.: Dist - 5510016

Sample Type: Grab
Sample Matrix: Water
Date/ Time Sampled Begin:
Date/ Time Sampled: 03-Nov-2021 11:35By Michelle Jones

Test Parameter	Result	DLR	Unit	Dilution	Batch	Prepared	Analysis Date	Method	Notes
Residual Chlorine	ND	0.020	mg/L	1	AK10309	11/03/2021	11/03/2021	Hach (Field Measur.)	
Total Coliforms	<1.1	1.1	MPN/100 ml	1	AK10324	11/03/2021	11/05/2021	SM 9221 B,C	
Total E. Coli	<1.1	1.1	MPN/100 ml	1	AK10324	11/03/2021	11/05/2021	SM 9221 B,C	
Fecal Coliforms	<1.1	1.1	MPN/100 ml	1	AK10324	11/03/2021	11/05/2021	SM 9221 B,C	

MMO-MUG-P/A - Total Coliform and E.Coli Test in Drinking Water by MMO-MUG, using Standard Method 22nd Edition.

The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1.1 (for MTF method) to meet drinking water requirements.

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.

RESPECTFULLY SUBMITTED,



Jonathan H.V. Le, Laboratory Director

Aqualab

P.O. BOX 356
Twain Harte, CA 95383
(209) 586-3400

CERTIFICATE OF ANALYSIS

Page 3 of 4

Attention: Dave Roy
Sierra Park Water Co/Oddfellows Sierra
PO Box 424
Mi Wuk Village, CA 95346

Notes and Definitions

<u>Item</u>	<u>Definition</u>
-------------	-------------------

Dry - Sample results reported on a dry weight basis.

ND - Analyte NOT DETECTED at or below the reporting limit.

DLR - Detection Limit for Purpose of Reporting. Exceptional sample matrices or interferences may result in higher detection limits.

RPD - Relative Percent Difference

%REC - Percent Recovery

Source - Sample that was matrix spiked or duplicated.

The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.

RESPECTFULLY SUBMITTED,



Jonathan H.V. Le, Laboratory Director